

NOTICE

KISHTWAR TRANSMISSION LIMITED

Registered office: - DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Gurugram, Haryana-122008

CIN No.: U40106DL2021GOI380131

1. **Kishtwar Transmission Limited**, having its registered office **DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Gurugram, Haryana-122008**, which is incorporated under the Companies Act, 1956 has made up an application before the Central Electricity Regulatory Commission, New Delhi under sub section (1) of Section 15 of the Electricity Act , 2003 for grant of transmission license in respect of the transmission lines, sub stations and other assets, the details of which are given

Amount in Rs. Lakhs

Sl. No	Name of the line/ substation (location)	Line Length/Capacity	Levelized Transmission Charges	Commissioning Schedule	Remarks
1	(i) Establishment of 400 kV switching station at Kishtwar (GIS) along with 420 kV, 125 MVAR Bus Reactor at Kishtwar Switching Station by LILO of one circuit of Kishenpur – Dulhasti 400kV D/c (Quad) line (Single Circuit Strung). <ul style="list-style-type: none">• 400 kV switching station with 420 kV, 125 MVAR Bus Reactor – 1 Nos.• Reactor Bay-1 Nos. Future Scope: Space for <ul style="list-style-type: none">• 765/400 kV ICT along with bays – 3 Nos.• 400/220 kV ICT along with bays – 2 Nos.• 400/132 kV ICT along with bays – 2 Nos.• 765 kV line bays along with switchable line reactor – 6 Nos.• 400 kV Line bays – 8 Nos.• 220 kV Line bays – 2 Nos.• 132 kV Line bays – 2 Nos.• 765 kV Reactor along with bays-1 Nos.• 400 kV Reactor along with bays – 1 Nos.	400kV	3884.6	Matching Timeframe with Pakkaldul HEP (i.e 01.04.2025)	
2	LILO of one circuit of Kishenpur – Dulhasti 400 kV D/c (Quad) line at Kishtwar.	400kV / Approx 10			

3	2 Nos. of 400 kV bays at Kishtwar (GIS) for LILO of one circuit of Kishenpur – Dulhasti 400 kV D/c (Quad) line.	400kV			
4	1 No. of 400 kV line bay at Kishtwar (GIS) for 2nd circuit stringing of Kishtwar- Kishenpur section	400kV			
5	2*200MVA, 400/132 kV ICT along with associated bays at Kishtwar Pooling Station 200MVA, 400/132 kV ICT-2 nos. 400kV ICT bays- 2nos. 132kV ICT bays- 2nos	400/132 kV ICT		Matching Timeframe of Kishtwar Pooling Station	
6	4 nos of 132kV Line bays at Kishtwar (GIS) Pooling Station	132kV			

2. Complete application and other documents filed before the commission are available on the website <https://www.sterlitepower.com/> for access of any person. The application can also be inspected at the office of the company at DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Sector-20, Gurgaon, Haryana-122008 with Mr. Balaji Sivan or Office of the commission in accordance with the procedure specified by the commission.
3. Objections and suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, 3rd and 4th Floor, Chandralok Bhawan, 36, Janpath, New Delhi-110001 (or other address where the office of the commission is situated), with a copy to the applicant at the address of its corporate office within 30 days of publication of this notice in the newspaper.

Place: Gurgaon
Date: 17.12.2022

Sd/-
Balaji Sivan
Director