

NOTICE

BEAWAR TRANSMISSION LIMITED

Registered office: - DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Gurugram, Haryana-122008 CIN No.: U40106DL2022GOI397400

1. **Beawar Transmission Limited**, having its registered office **DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Gurugram, Haryana-122008**, which is incorporated under the Companies Act, 1956 has made up an application before the Central Electricity Regulatory Commission, New Delhi under sub section (1) of Section 15 of the Electricity Act , 2003 for grant of transmission license in respect of the transmission lines, sub stations and other assets, the details of which are given

Amount in Rs. Million

Sl. No	Name of the line/ substation (location)	Line Length/Capacity	Levelized Transmission Charges	Commissioning Schedule	Remarks
1	<p>Establishment of 2x1500MVA 765/400kV Substation at suitable location near Beawar along with 2x330 MVAr 765kV Bus Reactor & 2x125 MVAr 420kV Bus Reactor.</p> <p>765/400kV 1500 MVA ICTs: 2 nos.</p> <p>(7x500 MVA, including one spare unit)</p> <p>330 MVAr, 765 kV bus reactor- 2 nos.</p> <p>(7x110 MVAr, including one spare unit)</p> <p>765kV ICT bays – 2 nos.</p> <p>400 kV ICT bays – 2 nos.</p> <p>765 kV line bays – 6 nos.</p> <p>400kV line bay – 2 nos.</p> <p>765kV reactor bay – 2 nos.</p> <p>125 MVAr, 420kV bus reactor – 2 nos.</p> <p>420 kV reactor bay – 2 nos.</p> <p>Future provisions: Space for</p> <p>765/400kV ICTs along with bays: 2 nos.</p> <p>765kV line bay along with switchable line reactor: 8nos.</p>	765kV, 330MVAR	2749.39	18 Months from 20.09.2023 (Effective Date)	



	765kV Bus Reactor along with bays: 2 nos. 400/220 kV ICTs along with bays: 2nos. 400 kV line bays along with switchable line reactor: 4 nos. 400kV Bus Reactor along with bays: 1 no. 220 kV line bays: 4 nos.			
2	LILO of both circuit of Ajmer-Chittorgarh 765 kV D/c at Beawar	765kV, ~ 45 Kms		
3	LILO of 400kV Kota –Merta line at Beawar	400kV, ~ 20 Kms		
4	Fatehgarh-3– Beawar 765 kV D/c along with 330 MVAR Switchable line reactor for each circuit at each end of Fatehgarh-3– Beawar 765 kV D/c line Switching equipment for 765 kV 330 MVAR switchable line reactor –4 nos. 765 kV, 330 MVAR Switchable line reactor- 4 nos.	765kV, ~ 350 Kms		
5.	± 2x300MVAR STATCOM, 4x125 MVAR MSC, 2x125 MVAR MSR at Fatehgarh- 3 PS along with 2 nos. of 400 kV bays at Fatehgarh-3 PS	300 MVAR		24 Months from Effective date (20.09.2023)

- Complete application and other documents filed before the commission are available on the website <https://www.sterlitepower.com/> for access of any person. The application can also be inspected at the office of the company at DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Sector-20, Gurgaon, Haryana-122008 with Mr. Balaji Sivan or Office of the commission in accordance with the procedure specified by the commission.
- Objections and suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, 3rd and 4th Floor, Chandralok Bhawan, 36, Janpath, New Delhi-110001 (or other address where the office of the commission is situated), with a copy to the applicant at the address of its corporate office within 30 days of publication of this notice.

Place: Gurgaon
Date: 26.09.2023


Balaji Sivan
Director

