

NOTICE

NEEMRANA II KOTPUTLI TRANSMISSION LIMITED

(DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Gurugram, Haryana-122008

CIN No.: U42201DL2023GOI415846)

1. **Neemrana II Kotputli Transmission Ltd**, having its office at **DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Gurugram, Haryana-122008**, which is incorporated under the Companies Act, 2013 has made up an application before the Central Electricity Regulatory Commission, New Delhi under sub section (2) of Section 15 of the Electricity Act , 2003 for grant of transmission license in respect of the transmission lines, sub stations and other assets, the details of which are given

Amount in Rs. Million

Sl. No	Name of the line/ substation (location)	Line Length/Capacity	Levelized Transmission Charges	Commissioning Schedule	Remarks
1	<p>Establishment of 765/400 kV, 4x1500 MVA (along with one spare unit of 500 MVA) Neemrana-II S/s along with 2x330 MVA (765 kV) Bus Reactor (along with one spare unit of 110 MVA) & 2x125 MVA (420kV) Bus Reactor at a suitable location near Neemrana</p> <ul style="list-style-type: none">• 765/400 kV 1500 MVA ICTs – 4 nos. (13x500 MVA including one spare unit)• 330 MVA Bus Reactor-2 nos. (7x110 MVA, including one spare unit)• 765 kV reactor bays- 2 nos.• 125 MVA, 420kV bus reactor - 2 nos.• 420 kV reactor bays - 2 nos.• 765 kV ICT bays – 4 nos.• 400 kV ICT bays – 4 nos.• 400 kV line bays - 6 nos. (4 nos. for LILO of Gurgaon -Sohna Road D/c line & 2 nos. for Kotputli D/c line) <p>Future provisions: Space for</p> <ul style="list-style-type: none">• 765/400kV ICT along with bays- 2 nos.• 765 kV line bays along with switchable line reactors – 12 nos.• 765 kV Bus Reactor along with bay: 1 no.• 400 kV line bays along with switchable line reactor –6 no.• 400 kV Bus Reactor along with bay: 1 no. <p>400kV Sectionalization bays: 2 sets</p>	765/400 kV, 330MVA	1694.65 Million per annum	24 Months from 27.12.2023 (Effective Date)	

2	Neemrana-II -Kotputli 400 kV D/c line (Quad)	400 kV, ~ 70 Kms			
3	2 no. of 400 kV line bays at Kotputli • 400 kV line bays at Kotputli - 2 nos.	400kV line bays			
4	LILo of both ckts of 400 kV Gurgaon (PG) - Sohna Road (GPTL) D/c line (Quad) at Neemrana-II S/s	400 kV, ~ 85 Kms			

- Complete application and other documents filed before the commission are available on the website <https://www.sterlitepower.com/> for access of any person. The application can also be inspected at the office of the Company at DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Sector-20, Gurgaon, Haryana-122008 with Mr. Balaji Sivan or Office of the commission in accordance with the procedure specified by the commission.
- Objections and suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, 3rd and 4th Floor, Chandralok Bhawan, 36, Janpath, New Delhi-110001 (or other address where the office of the commission is situated), with a copy to the applicant at the address of its corporate office within 30 days of publication of this notice.

Place: Gurgaon
Date: 04.01.2023


Balaji Sivan
Director

